

"EVERY LIKKLE MEK A MUCKLE"

Smart ideas for conserving energy in your Business

Refrigeration

- Check and adjust (*if necessary*) automatic defrost cycles on refrigerators. Open only as necessary.

Lighting

- Use compact fluorescent lights (CFL's) or T8 bulbs with electronic ballast starters instead of incandescent bulbs (**70% more efficient**).
- Install occupancy sensors in bathrooms and other rooms to control lighting (**Heat sensors are best**).
- Install solar lights where feasible.

A/Cs Maintenance

- Ensure proper maintenance of A/C unit (**clean filters often**).
- Utilize fans on A/Cs in ATMs or turn thermostat to no less than 78° F/25°C.
- Use automatic timers on A/Cs to turn off units at least 15 – 30 minutes before leaving office.



A message from the Scientific Research Council

Regional Focal Point for the

Caribbean Energy Information System

